

OIL INDIA LIMITED
(A Government of India Enterprise)
P.O. Duliajan, Pin – 786602
Dist-Dibrugarh, Assam

Ref: MM/ALB/FD09/045-A

Date: 21.02.2017

CORRIGENDUM

ADDENDUM No.01_ Dated 21.02.2017

To

Tender No. SDG3498P17/09

This Addendum No.01 dated 21.02.2017 to Tender No. SDG3498P17/09
is issued to amend the following technical specification clause as under:

| <i>Clause Ref</i> | <i>Existing Clause</i> | <i>Amended as</i> |
|--|--|--|
| <i>Annexure-I, Clause B (Item description), Point No. B. (ii)</i> | Motor Cables: Each motor shall be supplied complete with 4X6 mm ² , polyolefin inner insulation, CPE outer jacket insulated motor cables of minimum 12mt length each with stranded flexible copper conductors. Cable should conform to BIS/CSA & UL & other relevant standards. No joints shall be allowed. The cables running out of the motor along the pipe up to the starter panel shall be driven in non-corrosive conduits to protect against mechanical damage. Suitable clamps / supports shall be provided along the entire length of the cable. | Motor Cables: Each motor shall be supplied complete with minimum 3X5 mm² , polyolefin inner insulation, CPE outer jacket insulated motor cables of minimum 12 feet length each with stranded flexible copper conductors. Cable should conform to BIS/CSA & UL & other relevant standards. No joints shall be allowed. The cables running out of the motor along the pipe up to the starter panel shall be driven in non-corrosive conduits to protect against mechanical damage. Suitable clamps / supports shall be provided along the entire length of the cable. |

All other Terms & Conditions of the Bid Document remain unaltered.

sd/-
Amrit Loushon Bora
Sr. Purchase Officer(FD)
For Dy. GM Materials
For Resident Chief Executive