



## **OIL INDIA LIMITED**

(A Government of India Enterprise)  
P.O. Duliajan - 786602, Assam, India  
FAX: 0374-2800533; Ph: 0374-2808719;

E-mail: [ranjan\\_barman@oilindia.in](mailto:ranjan_barman@oilindia.in); [erp\\_mm@oilindia.in](mailto:erp_mm@oilindia.in)

### **CORRIGENDUM**

Ref: HM/IP/RB/DID1538L20/05

Dated: 17.07.2019

**Sub: Amendment No. 5 dated 17.07.2019 to Annexure-IA of Tender No. DID1538L20/L3**

Dear Sirs,

This **Amendment No. 5** to the **Annexure-IA** of the subject Tender has been issued to **amend** the following specifications of **item no. 10** as under in place of existing:

SL. NO.	Existing clause ( with clause no./page number)	Amended Clause
1	Annexure-IA page- 5 of 14, <b>Point iv.</b> Soft starter panels- Individual soft starter cubicles shall have individual soft starter units. Other components such as cubicle incomer MCCB, earth leakage protection with the MCCB, main (starting) contactor, running contactor, thermal overload relay, remote/local selector switch, start/stop pushbuttons, LED indications, intrinsically safe barriers etc. shall be as in the normal star/delta or DOL starter panels.	Annexure-IA page- 5 of 14, <b>Point iv.</b> Soft starter panels- Individual soft starter cubicles shall have individual soft starter units. Other components such as cubicle incomer MCCB, earth leakage protection with the MCCB, main (starting) contactor, running contactor, thermal overload relay, remote/local selector switch, start/stop pushbuttons, LED indications <del>intrinsically safe barriers</del> etc. shall be as in the normal star/delta or DOL starter panels.

**Bidders are requested to note all amendments & original NIT while quoting.**

All other terms and conditions of the Tender remain unchanged.

Yours faithfully,  
OIL INDIA LIMITED,



**(RANJAN BARMAN)**  
**DGM (IP)**  
**For GM-Materials (HOD)**