



**CORRIGENDUM**

**Addendum No. 02 dated 11.08.2020**

**to**

**TENDER NO. SJI4441P21**

- 1.0 This addendum is issued to amend the following clauses of the tender in lieu of existing.

<b>Sl. No.</b>	<b>Page No.</b>	<b>Clause No.</b>	<b>Existing Tender Clause &amp; Description</b>	<b>Amended Tender Clause &amp; Description</b>
1	Page 6 of 26	ANNEXURE-IA Item: 10 (OC000574) c)	c) Ladders with hand rails at appropriate locations (one outside the tank for climbing on the tank and the other one inside the tank; ladders should not be placed on the valves.	c) Ladders with hand rails at appropriate locations (one outside the tank for climbing on the tank and the other one inside the tank; ladders should not be placed on the valves. A removable type Railing of 1.2 m height to be provided on top at around the tanks with proper exit.

- 2.0 All other Terms & Conditions of the Bid Document remain unaltered.

sd/-  
A. D. SINGH  
Manager (C&P)