

### **ADDENDUM**

- Please find Layout drawing attached as per Annexure-Z
- The top control room is at the first floor and the height of the topmost point of the control room from ground is 8 M. The cylinders shall be kept at the ground level.
- Bid Closing Date and the last date of receipt of application for Submission/ Exemption of tender fee against the following e-tender has been extended as shown below.

<b>e-Tender no.</b>	<b>Material Description</b>	<b>Revised BC date</b>	<b>Last date of receipt of application for Submission/Exemption of Tender Fee.</b>
SKI6639P18/08	Supply, Installation and commissioning of Clean agent Fire Extinguishing system for LPG recovery plant	02.02.2018	27.01.2018

All other terms and Conditions remain unchanged.

# LPG Top Control Room

