

THIS AMENDMENT TO THE NIT (SDI5970P18) IS ISSUED TO AMEND THE FOLLOWING CLAUSES OF SPECIFICATIONS. BIDDERS ARE REQUESTED TO NOTE ALL AMENDMENTS & ORIGINAL NIT WHILE QUOTING.

9.19 02 Nos. hose reel **with minimum 25 mm x 30 m long high pressure hose (30 bar working pressure) fitted** with Variable Flow Hydro Chem Nozzle **(1.5" (F)NST water inlet, 1" (F)NST dry chem inlet)** & Parker make hose shall be provided at both side of Unit for DCP discharge at easily accessible location so as to facilitate quick pulling with throw of 10 M at 45° & capable of discharging minimum 2.5 Kg/sec. Hydro-Chem/ DCP Variable Flow Nozzle shall be M/s. Williamsfire, USA/ ElkhartBrass, USA/ Task Force Tips (TFT), USA/ Akron Brass.

NOTE:

Bidders should submit their bids (preferably in tabular form) explicitly mentioning compliance / non compliance to all the NIT terms and conditions of NIT.