

Addendum-3

In addition to Addendum-1 and Addendum-2, please find following additional data of e-tender SKI6639P18/08 provided as clarification against queries asked:

Query	Clarification. Additional data of SKI6639P18/08
Regarding Dimensions	Height of floor from ground level- 5M Height between floor and ceiling- 3 M Height of control room floor from cylinder location- 5M
Regarding Technical Specifications	Technical specification provided in Annexure AAA of document SKI6639P18 already uploaded. All equipment shall be approved by UL/FM/Vds/LPC and cylinders along with cylinder valve assemblies shall be seamless and PESO/CCoE approved. The Clean Agent system to be provided shall meet the requirements of NFPA-2001 (2012 edition). Fire Detection system is included in bidder's scope.
Height of False floor, Room height and above ceiling.	Height of floor from ground level- 5 M Room height- 3 M
Fire Detection system included in bidder's scope or not ?	Yes
Which approvals acceptable for clean agent system like UL/FM, Vds/LPCB etc.?	All equipment shall be approved by UL/FM/Vds/LPC and cylinders along with cylinder valve assemblies shall be seamless and PESO/CCoE approved.
Any Explosion proof equipment included in bidder's scope or not?	No; provided it is not a part of your system.
Other than Inert gas any other gases is acceptable or not, like FM200, NOVEC 1230 etc.	The Clean Agent system to be provided shall meet the requirements of NFPA-2001 (2012 edition).

All other terms and conditions of the tender remain unchanged.