



CORRINGENDUM NO. 1 TO SKI 7578P18

This amendment is issued to amend the Technical Specifications of Tender Number **SKI 7578P18/04** dated **30.03.2018** as under instead of existing:

REVISED TECHNICAL SPECIFICATIONS

Sr. No. ITEM REQUIREMNT	Existing Technical Specifications	Revised Technical Specifications
2.04	Siphon Tubes (Inlet & Outlet) SS-316 or Brass as per IS:407	Siphon Tube SS-316 or Brass as per IS:407
2.05	Discharge Nozzle SS-316 or Forged Brass as per IS:6912 grade FLB (Latest Revision)	Discharge Nozzle SS-316 or Forged Brass as per IS:319 (Latest Revision)
2.08	Safety Pin SS-316	Safety Pin SS-316/ ASTM 201/ SUS 201
9.1. e.	Complete Plunger Assembly - 20 Nos	Complete Valve Assembly - 20 Nos.
9.1. k.	Refilling kit for refilling of Fire Extinguishers. - 01 Nos	Nitrogen Filling Kit/ equipment -1 (one) Set. Made o of SS 304 body with good surface finish. Provided with Safety Valves, Pressure Gauge (Range: 0 to min 25 kg per cm², SS dial, and glycerol filled suitably mounted), all fittings & Pipes of SS-304, Pressure Transducer, Filling Gun with NRV & 2 Hoses. Along with Nitrogen Cylinder, approved PESO. Powers supply 230 V AC to 24V DC., Relay Card 2 Nos,

		<p>Pressure meter & on/Off Switch, Emergency Switch, Solenoid Valve 24V DC and all other necessary accessories required to refill.</p> <p>Spares to be supplied with kit: (i) Safety Valves- 2 Nos, (ii) Pressure Gauge- 2 Sets (iii) All SS-304 fittings & Pipes- 2 Sets, (iv) Pressure Transducer- 2 Nos, (v) Filling Gun with NRV & 2 Hoses – 2 Sets, (vi) Relay Card- 4 Nos. (vii) Pressure meter & on/Off Switch- 2 sets., (viii) Emergency Switch- 2 Nos. (ix) Solenoid Valve 24V DC. – 2 Nos., (x) Any other items which are necessary.</p>
--	--	--

3.0 All other terms and conditions of the tender will remain unchanged.