

OIL INDIA LIMITED
(A Government of India Enterprise)
P.O. Duliajan, Pin – 786602
Dist-Dibrugarh, Assam

CORRIGENDUM NO. 3

Corrigendum No. 3 dated 23.08.2023 to **IFB No. CDI3899P24** for **“Implementation of Isolated Lightning Protection System to Fixed Roof Crude Oil Storage Tanks at Intermediate Tank Farm (ITF), of Oil India Limited.”**

This Corrigendum is issued to notify the following:

1. Revised BEC BRC **document has been uploaded in place of existing.**
2. Revised SCC **document has been uploaded in place of existing.**
3. Responses to the queries are **uploaded as Annexure I.**
4. Following are the changes made in the revised BEC BRC and SCC from that of the original BEC BRC of the tender.:

| Clause Sl. No. | Approved BEC BRC | Revised BEC BRC |
|------------------|---|--|
| BEC Clause 1.2.1 | Bidder must have experience of successfully completing at least one SIMILAR work of minimum value Rs. 1,57,16,000 (Rupees One Crore Fifty-Seven Lakh Sixteen Thousand) only in previous 07 (seven) years reckoned from the original bid closing date with PSUs / Central Government / State Government Organization / Public Limited Company. <p style="text-align: center;"><u>OR</u></p> Bidder must have experience of successfully completing implementation of Isolated Lightning Protection System to at least 4 Nos of Crude oil / Petroleum product Storage Tanks of minimum diameter 20-meter. | Bidder must have experience of successfully completing at least one SIMILAR work of minimum value Rs. 1,57,16,000 (Rupees One Crore Fifty-Seven Lakh Sixteen Thousand) only in previous 07 (seven) years reckoned from the original bid closing date with PSUs / Central Government / State Government Organization / Public Limited Company. <p style="text-align: center;"><u>OR</u></p> Bidder must have experience of successfully completing implementation of Isolated Lightning Protection System to at least 4 Nos of Crude oil / Petroleum product Storage Tanks of minimum diameter 20-meter only in previous 07 (seven) years reckoned from the original bid closing date with PSUs / Central Government / State Government Organization / Public Limited Company. |
| BEC Clause 1.2.2 | The Bidder must have an Electrical Contractors' License issued or recognized by the Electrical Licensing Board, Government of | The Bidder must have an Electrical Contractors' License issued or recognized by the Electrical Licensing Board, Government of Assam. This Electrical Contractor's license shall be valid as on original bid closing date. |

OIL INDIA LIMITED
 (A Government of India Enterprise)
 P.O. Duliajan, Pin – 786602
 Dist-Dibrugarh, Assam

| | | |
|--|--|---|
| | <p>Assam. This Electrical Contractor's license shall be valid as on original bid closing date. Bidder must submit a copy of valid Electrical Contractors' License in support of above.</p> <p>Bidders having valid Electrical Contractors' License issued by any State Government Electrical Licensing Board of India other than that of Assam can also participate in the tender provided such bidders submit a copy of their valid electrical contractor's license along with an undertaking stating that on award of contract to them they will submit either a valid Electrical Contractors' License issued by Electrical Licensing Board, Government of Assam in their name or get their Electrical Contractors' License recognized / endorsed by Electrical Licensing Board, Government of Assam for executing the job at Assam within 30 days from date of award of the contract and the same will be subsequently renewed till the completion of the contract.</p> | <p>Bidder must submit a copy of valid Electrical Contractors' License in support of above.</p> <p>Bidders having valid Electrical Contractors' License issued by any State Government Electrical Licensing Board of India other than that of Assam can also participate in the tender provided such bidders submit a copy of their valid electrical contractor's license along with an undertaking stating that on award of contract to them they will submit either a valid Electrical Contractors' License issued by Electrical Licensing Board, Government of Assam in their name or get their Electrical Contractors' License recognized / endorsed by Electrical Licensing Board, Government of Assam for executing the job at Assam within 30 days from date of award of the contract and the same will be subsequently renewed till the completion of the contract.</p> <p>If valid 'Electrical Contractor's License' is not available at the time of bidding, contractor must furnish a declaration stating the following:</p> <p>(1) We have applied for Electrical Contractor's License from _____; documentary evidence is enclosed.</p> <p>(2) A copy of valid Electrical Contractor's License will be furnished by us positively within 15 days from the date of issuance of LOA.</p> <p>(3) We understand that failure to produce a valid Electrical Contractor's License within 15 days from the date of issue of LOA will result rejection of the offer and action shall be taken as per Banning Policy of OIL.</p> |
| <p>SCC Clause 5 TIME PERIOD OF WORK COMPLETION (Page 83 of 119)</p> | <p>Total time for completion of the job will be 06 months. One month for approval for all relevant drawings and documents and 05 months for</p> | <p>Total time for completion of the job will be 08 (eight) months. One month for approval for all relevant drawings and documents and 07 months for supply, installation, testing and commissioning of LPS at site.</p> |

OIL INDIA LIMITED
 (A Government of India Enterprise)
 P.O. Duliajan, Pin – 786602
 Dist-Dibrugarh, Assam

| | | |
|---|--|--|
| | <p>supply, installation, testing and commissioning of LPS at site.</p> <p>Delay in completion of the work within the stipulated 6 months' time shall invite imposition of Liquidated Damages (LD) as spelt out in the GCC.</p> | <p>Delay in completion of the work within the stipulated 08 months' time shall invite imposition of Liquidated Damages (LD) as spelt out in the GCC.</p> |
| <p>SCC Clause 1.4 DETAILS OF THE TANKS (Page 74 of 119)</p> | <p>Note: (a) Actual tank pad height from dyke plinth, tank pad diameter and tank height may vary approximately by 5% tank to tank, (b) Tank height does not include height of railings over the tank</p> | <p>Tank pad dia have been modified and also height of Tank including vent & Railings from pad have been added in the table. The modified table is attached below as Table 1 "Details of Tanks".</p> <p>Note: (a) Actual tank pad height from dyke plinth, tank pad diameter and tank height may vary approximately by 5% tank to tank, (b) Tank height does not include height of railings over the tank</p> |
| <p>SCC Clause 1.12 (f) (Page 77 of 119)</p> | <p>The design of earth pit should be based on soil resistivity. In no case, its value should go beyond 2 (two) Ohm for individual earth pit. Soil resistivity test shall be done by the vendor.</p> | <p>The design of earth pit should be based on soil resistivity. Earth resistance value for individual earth pit shall be ≤ 4 (four) Ohm. Soil resistivity test shall be done by the vendor.</p> |

5. Extension of dates:

- Original Date & time of Bid Submission: **11:00 hours of 10.08.2023**
- Extended Bid Closing Date & time: **11:00 hours of 31.08.2023**

All other terms and conditions of the Bid Document remain unchanged. Details can be viewed at <https://etender.srm.oilindia.in/irj/portal> and www.oil-india.com.

Senior Manager-Contracts (S)